

© Copyright Statement

All rights reserved. All material in this document is, unless otherwise stated, the property of **FPC International, Inc.** Copyright and other intellectual property laws protect these materials. Reproduction or retransmission of the materials, in whole or in part, in any manner, without the prior written consent of the copyright holder, is a violation of copyright law.

FIELD TEST.

EVALUATION OF
FTC COMBUSTION CATALYST
AT
BELLEVUE GOLD MINE
POWER STATION

December 1992

Report prepared by:

R.A. Platt
Fuel Technology Pty Ltd
70 Adelaide Street
FREMANTLE WA 6160

Tel: (09) 335 6446
Fax: (09) 430 5403

ACN 005 945 915

CONTENTS

Summary	Page 1
Test procedure	Page 1
Results - Carbon Balance	Page 2
- Specific Fuel Consumption	Page 4
Conclusions	Page 5

Appendices

- A. Carbon Balance - Computer Printouts
- B. Specific Fuel Consumption - Data Sheets

* * * *

Summary

Bellevue Gold Mine has been using FTC combustion catalyst for a number of years, and the cleanliness of engine combustion spaces has been acknowledged. However, management has expressed concerns as to the economic viability of the product as it relates to fuel efficiency.

A decision was made in July to cease treatment, and Fuel Technology offered to measure combustion change, if any, after three months non fuel treatment, employing the Specific Fuel Consumption method and taking into account known variables, such as temperature and fuel density.

Concurrent with this study Fuel Technology also trialled its new technology catalyst developed and patented in Australia. Both products show a fuel efficiency benefit in the range 2.3% to 5.6% after corrections for variables.

TEST PROCEDURE

The test method employed, Specific Fuel Consumption (SFC) is an engineering test whereby the absolute amount of fuel consumed by the equipment at specified power settings is determined by volume or weight measurement. Volumes are corrected for temperature and density variations.

Carbon Balance measurement (CB) tests were also made on the FTC+ product. This method involves calculation of the mass of carbon in the exhaust, as a measure of the fuel being burned. The elements measured in this test include the exhaust gas composition, its temperature and the gas flow rate calculated from the pressure and exhaust stack cross sectional area. This is an engineering standard test (AS 2077-1982). Concurrent with this test procedure Bosch Smoke measurements are also conducted, as another method of verifying improved combustion.

Treated fuel tests were conducted on Units Nos 1, 4 & 5 on 5 July 1992, prior to treatment ceasing, and return to baseline tests on 4 October 1992. Also included in the baseline tests were new gensets Units Nos 2 & 3.

The tests were conducted on Sundays, when the mine power requirement is steady, eg no winding motor running on an intermittent basis. However, there are still some load variations due to compressor and other equipment starts.

Units Nos 2 & 3 were tested by baseline and treated measurements between the hours 5 pm to 11 pm when the load was most steady.

FTC+ was tested on 25 October 1992, Carbon Balance tests were conducted with our Horiba infra red analyser, smoke measurements by means of our Bosch instrumentation.

The SFC tests were conducted employing our Microvip MK 1.2 Energy Analyser connected to each generators section of the switchboard. Fuel flow was measured by the individual flow meters fitted to each engine. Elapsed time by a quartz crystal digital stop watch.

RESULTS

Carbon Balance Measurements

CB tests were conducted by Infra red analysis for untreated baseline and FTC+ treated fuel. Table I sets out the results. Table II sets out the results corrected for load variation between baseline and treated tests.

Note, Unit No 1 is a Cummins KTA38, all other units are Cummins KTA50. The engines are a vee form and exhaust discharges via individual trunking and exhaust stacks.

TABLE I

CB Test Results FTC+ - Carbon Flow (g/s)

Unit No	Load kW		Carbon Flow		Change %
	Baseline	Treated	Baseline	Treated	
1	360	380	16.157	16.896	+ 4.6
2	560	575	20.462	19.170	- 6.3
3	590	580	21.772	20.097	- 7.7
5	580	575	21.617	19.879	- 8.0
Average			20.002	19.011	- 4.9

CB Test Results FTC+ - Carbon Flow Corrected for Load (kg/kWh)

Unit No	Load kW		Carbon Flow		Change %
	Baseline	Treated	Baseline	Treated	
1	360	380	0.1616	0.1610	-1.0
2	560	570	0.1316	0.1215	-7.7
3	590	580	0.1334	0.1248	-6.4
5	580	575	0.1342	0.1244	-7.3
Average			0.1402	0.1329	-5.2

The Bosch Smoke measurements taken during FTC Treated, baseline and treated FTC+ tests are described in Table III.

TABLE III

Bosch Smoke Comparison

Unit No	Load kW	Bosch Reading		FTC+ Treated 25/10/92
		FTC Treated 5/7/92	Baseline 4/10/92	
1L	360/380	1.0	1.1	0.7
1R	360/375	0.6	1.5	1.0
2L	560/560	N/A	0.9	1.4
2R	560/575	N/A	1.4	1.2
3L	595/580	N/A	1.0	1.0
3R	580/580	N/A	0.7	1.0
4L	580/NA	0.9	N/T	N/T
4R	580/NA	1.0	N/T	N/T
5L	580/580	0.6	0.8	0.7
5R	580/570	0.7	0.5	0.7
Average		0.8	0.99	0.96

The deterioration in smoke following withdrawal of FTC from the fuel is 23.75%. The average improvement following addition of FTC + is 3%, however, our general experience is that smoke variations are not measurable in time periods less than three months.

SPECIFIC FUEL CONSUMPTION MEASUREMENTS

SFC tests were conducted on Units Nos 1, 4 & 5 on 5 July 1992 running on FTC. Return to baseline tests were conducted on Units Nos 1, 4 & 5 on 4 October, and the new units Nos 2 & 3. FTC+ treated tests were conducted on Units Nos 2, 3, 4 & 5 on 25 October. Units Nos 4 & 5 having high hours, Units 2 & 3 low hours.

The Summary of the test results shown in Table IV are volumetric measurements. Table V shows the data corrected for fuel density and temperature.

TABLE IV

SFC Test Results L/kWh

Unit No	FTC Treated 5/7/92	Baseline 4/10/92	Change %	FTC+Treated 25/10/92	Change %
1	0.2788	0.2886	+ 3.5	N/T	
2	N/A	0.2859		0.2804	-1.9
3	N/A	0.2872		0.2814	-2.0
4	0.2657	0.2350*	-11.5	0.2402	+2.2
5	0.2764	0.2872	+ 3.9	0.2751	-4.2

* This very large variation in efficiency between tests and also when compared to sister engines suggests a fuel meter error.

TABLE V

SFC Test Results kg/kWh

Unit No	FTC Treated 5/7/92	Baseline 4/10/92	Change %	FTC+Treated 25/10/92	Change %
1	0.2320	0.2384	+2.8		
2	N/A	0.2361		0.2319	-1.8
3	N/A	0.2384		0.2321	-2.6
4	0.2120	0.1932	-8.9	0.1967	+1.8
5	0.2291	0.2366	+3.3	0.2261	-4.4

Reviewing the above data and excluding the results of Unit No 4 which appear anomalous, the return to baseline following cessation of FTC treatment shows a decline in efficiency in the range 2.8% to 3.3%. Following addition of FTC+ the new engines 2 & 3 show an improving efficiency averaging 2.2%. Engine 5 shows an efficiency gain of 4.4%.

Cummins performance data stipulates that for every 10°C change in aspirating air temperature, efficiency gains or loses 1%. Adjusting the results for the temperature variables measured are shown in Table VI.

TABLE VI
Corrections for Ambient Temperature Change

Unit No	FTC Treated 2/7/92 °C	Baseline 4/10/92 °C	Indicated Correction	FTC+Treated 5/10/92 °C	Indicated Correction
1	16.0	22.0	+0.6		
2	N/A	18.0		22.0	+0.4
3	N/A	18.0		24.0	+0.6
4	15.5	24.0	+0.85	34.0	+1.0
5	15.0	24.5	+0.95	36.5	+1.2

Table VII shows the corrected engine efficiency change as a result of applying the corrections in table VI to the values in table V.

TABLE VII
SFC Corrected Efficiency Gains

Unit No	FTC Treated 5/7/92	Baseline 4/10/92	Change %	FTC+Treated 25/10/92	Change %
1	*	*	+2.2	*	
2		*		*	-2.3
3		*		*	-3.2
4	*	*	-9.75	*	+0.8
5	*	*	+2.35	*	-5.6

CONCLUSIONS

Based on CB test results the FTC+ fuel treatment indicates an average 5.2% reduction in carbon flow compared to the baseline values.

The smoke test comparisons indicate a 23.7% benefit in favour of FTC and 3% for FTC+. However, the test duration with FTC+ of three weeks is low and two of the test engines are new which will impact on the results.

The SFC test results, excluding engine No 4 indicate a decreased efficiency following removal of FTC from the fuel, and an average 3.7% efficiency gain on introducing FTC+.

These results compare favourably with our experience in similar stations operating Cummins gensets. The tests were conducted in the most careful and thorough manner possible in a commercial situation. On balance the FTC+ product appears to be performing better than the original FTC material.

Appendix A

CARBON BALANCE
COMPUTER PRINTOUTS

COMPANY : BELLEVUE GOLD MINE LOCATION : LEINSTER
 EQUIPMENT : GENSET UNIT NR. : 1 R/Bank
 ENG. TYPE : CUMMINS MODEL : KTA38
 RATING : FUEL : ADO

BASELINE DATE : 4.10.92

ENG. HOURS : 33204 ENG. RPM:
 AMB. TEMP (C) : 32 STACK(mm): 160
 BAROMETRIC(mb): 963 LOAD: 360 KW

	TEST 1	TEST 2	TEST 3	TEST 4	TEST 5	AVERAGE	% ST.DEV
PRES DIFF (Pa):	271	269	271	272	273	271	0.55
EXHST TEMP (C):	403.5	403.7	403.8	403.9	404.1	404	0.06
HC (ppm) :	10	10	10	10	10	10.0	0.00
CO (%) :	0.03	0.03	0.03	0.03	0.03	0.030	0.00
CO2 (%) :	6.83	6.83	6.83	6.83	6.83	6.83	0.00
O2 (%) :	10.34	10.33	10.33	10.33	10.30	10.33	0.15

CARB FLOW(g/s): 7.628 7.599 7.627 7.640 7.653 7.629 0.26

REYNOLDS NR. : 5.56E+04

TREATED TEST DATE : 25.10.92

ENG. HOURS : 33627 ENG. RPM:
 AMB. TEMP (C) : 45.4 STACK(mm): 160
 BAROMETRIC(mb): 958 LOAD: 370-380 KW

	TEST 1	TEST 2	TEST 3	TEST 4	TEST 5	AVERAGE	% ST.DEV
PRES DIFF (Pa):	268	269	268	268	268	268	0.17
EXHST TEMP (C):	428.9	429.3	429.3	429.4	429.4	429	0.05
HC (ppm) :	0	0	0	0	0	0.0	#DIV/0!
CO (%) :	0.03	0.03	0.03	0.03	0.03	0.030	0.00
CO2 (%) :	7.12	7.10	7.09	7.09	7.09	7.10	0.18
O2 (%) :	10.05	10.05	10.05	10.05	10.05	10.05	0.00

CARB FLOW(g/s): 7.735 7.726 7.701 7.700 7.700 7.712 0.22

REYNOLDS NR. : 5.42E+04 TOTAL HOURS ON TREATED FUEL : 423

PERCENTAGE CHANGE IN FUEL CONSUMPTION ((TREATED-BASE)/BASE*100) : 1.1 %

REMARKS:

 COMPANY : BELLEVUE GOLD MINE LOCATION : LEINSTER
 EQUIPMENT : GENSET UNIT NR. : 1 L/Bank
 ENG. TYPE : CUMMINS MODEL : KTA38
 RATING : FUEL : ADO

BASELINE DATE : 4.10.92

 ENG. HOURS : 33204 ENG. RPM:
 AMB. TEMP (C) : 32 STACK(mm): 160
 BAROMETRIC(mb): 963 LOAD: 360 KW

	TEST 1	TEST 2	TEST 3	TEST 4	TEST 5	AVERAGE	% ST.DEV
PRES DIFF (Pa):	346	348	347	345	346	346	0.33
EXHST TEMP (C):	392.3	392.5	392.6	392.8	393	393	0.07
HC (ppm) :	10	10	10	10	10	10.0	0.00
CO (%) :	0.03	0.03	0.03	0.03	0.03	0.030	0.00
CO2 (%) :	6.71	6.71	6.69	6.69	6.69	6.70	0.16
O2 (%) :	10.41	10.41	10.40	10.40	10.40	10.40	0.05
CARB FLOW(g/s):	8.540	8.563	8.525	8.499	8.511	8.528	0.29
REYNOLDS NR. :	6.34E+04						

 TREATED TEST DATE : 25.10.92

 ENG. HOURS : 33627 ENG. RPM:
 AMB. TEMP (C) : 45.4 STACK(mm): 160
 BAROMETRIC(mb): 958 LOAD: 370-380 KW

	TEST 1	TEST 2	TEST 3	TEST 4	TEST 5	AVERAGE	% ST.DEV	
PRES DIFF (Pa):	372	373	374	372	372	373	0.24	
EXHST TEMP (C):	427.4	427.8	428.1	428.4	428.5	428	0.11	
HC (ppm) :	0	0	0	0	0	0.0	#DIV/0!	
CO (%) :	0.03	0.03	0.03	0.03	0.03	0.030	0.00	
CO2 (%) :	7.16	7.16	7.17	7.17	7.17	7.17	0.08	
O2 (%) :	10.09	10.09	10.09	10.09	10.09	10.09	0.00	
CARB FLOW(g/s):	9.174	9.183	9.206	9.180	9.179	9.184	0.14	
REYNOLDS NR. :	6.39E+04	TOTAL HOURS ON TREATED FUEL :					423	

PERCENTAGE CHANGE IN FUEL CONSUMPTION ((TREATED-BASE)/BASE*100) : 7.7 %

REMARKS:

COMPANY : BELLEVUE GOLD MINE LOCATION : LEINSTER
 EQUIPMENT : GENSET UNIT NR. : 2 R/Bank
 ENG. TYPE : CUMMINS MODEL : KTA50
 RATING : FUEL : ADO

BASELINE DATE : 4.10.92

ENG. HOURS : 772 ENG. RPM:
 AMB. TEMP (C) : 28.4 STACK(mm): 200
 BAROMETRIC(mb): 965 LOAD: 560 KW

	TEST 1	TEST 2	TEST 3	TEST 4	TEST 5	AVERAGE	% ST.DEV
PRES DIFF (Pa):	196	198	195	195	198	196	0.77
EXHST TEMP (C):	451.1	451.3	451.4	451.6	451.7	451	0.05
HC (ppm) :	10	10	10	10	10	10.0	0.00
CO (%) :	0.03	0.03	0.03	0.03	0.03	0.030	0.00
CO2 (%) :	7.43	7.43	7.43	7.42	7.42	7.43	0.07
O2 (%) :	9.51	9.50	9.50	9.50	9.49	9.50	0.07

CARB FLOW(g/s): 10.666 10.719 10.637 10.621 10.702 10.669 0.39

REYNOLDS NR. : 4.58E+04

TREATED TEST DATE : 25.10.92

ENG. HOURS : 1273 ENG. RPM:
 AMB. TEMP (C) : 38 STACK(mm): 200
 BAROMETRIC(mb): 959 LOAD: 570-580 KW

	TEST 1	TEST 2	TEST 3	TEST 4	TEST 5	AVERAGE	% ST.DEV
PRES DIFF (Pa):	170	171	172	171	169	171	0.67
EXHST TEMP (C):	467.5	467.5	467.5	467.5	467.5	468	0.00
HC (ppm) :	10	10	10	10	10	10.0	0.00
CO (%) :	0.04	0.04	0.04	0.04	0.04	0.040	0.00
CO2 (%) :	7.77	7.77	7.76	7.76	7.76	7.76	0.07
O2 (%) :	11.00	10.98	10.98	10.96	10.96	10.98	0.15

CARB FLOW(g/s): 10.239 10.269 10.286 10.256 10.196 10.249 0.34

REYNOLDS NR. : 4.21E+04 TOTAL HOURS ON TREATED FUEL : 501

PERCENTAGE CHANGE IN FUEL CONSUMPTION ((TREATED-BASE)/BASE*100) : -3.9 %

REMARKS:

FUEL TECHNOLOGY PTY LTD

CARBON BALANCE RESULTS

COMPANY : BELLEVUE GOLD MINE LOCATION : LEINSTER
 EQUIPMENT : GENSET UNIT NR. : 2 L/Bank
 ENG. TYPE : CUMMINS MODEL : KTA50
 RATING : FUEL : ADO

BASELINE DATE : 4.10.92

ENG. HOURS : 772.4 ENG. RPM:
 AMB. TEMP (C) : 28.5 STACK(mm): 200
 BAROMETRIC(mb): 965 LOAD: 560 KW

	TEST 1	TEST 2	TEST 3	TEST 4	TEST 5	AVERAGE	% ST.DEV
PRES DIFF (Pa):	166	165	168	166	168	167	0.81
EXHST TEMP (C):	464.5	464.5	464.6	464.6	464.6	465	0.01
HC (ppm) :	20	20	20	20	20	20.0	0.00
CO (%) :	0.04	0.04	0.04	0.04	0.04	0.040	0.00
CO2 (%) :	7.44	7.42	7.45	7.46	7.48	7.45	0.30
O2 (%) :	9.21	9.21	9.20	9.20	9.20	9.20	0.06
CARB FLOW(g/s):	9.763	9.707	9.834	9.788	9.873	9.793	0.65

REYNOLDS NR. : 4.18E+04

TREATED TEST DATE : 25.10.92

ENG. HOURS : 1273 ENG. RPM:
 AMB. TEMP (C) : 38 STACK(mm): 200
 BAROMETRIC(mb): 959 LOAD: 560 KW

	TEST 1	TEST 2	TEST 3	TEST 4	TEST 5	AVERAGE	% ST.DEV
PRES DIFF (Pa):	142	144	142	143	144	143	0.70
EXHST TEMP (C):	471.8	471.9	471.9	471.9	472	472	0.01
HC (ppm) :	0	0	0	0	0	0.0	#DIV/0!
CO (%) :	0.05	0.05	0.05	0.05	0.05	0.050	0.00
CO2 (%) :	7.39	7.39	7.40	7.40	7.39	7.39	0.07
O2 (%) :	10.00	10.98	10.98	10.96	10.96	10.78	4.03
CARB FLOW(g/s):	8.891	8.946	8.896	8.927	8.946	8.921	0.30

REYNOLDS NR. : 3.84E+04

TOTAL HOURS ON TREATED FUEL : 500.6

PERCENTAGE CHANGE IN FUEL CONSUMPTION ((TREATED-BASE)/BASE*100) : -8.9 %

REMARKS:

COMPANY : BELLEVUE GOLD MINE LOCATION : LEINSTER
 EQUIPMENT : GENSET UNIT NR. : 3 R/Bank
 ENG. TYPE : CUMMINS MODEL : KTA50
 RATING : FUEL : ADO

BASELINE DATE : 4.10.92

ENG. HOURS : 822 ENG. RPM:
 AMB. TEMP (C) : 29.6 STACK(mm): 200
 BAROMETRIC(mb): 965 LOAD: 580 KW

	TEST 1	TEST 2	TEST 3	TEST 4	TEST 5	AVERAGE	% ST.DEV
PRES DIFF (Pa):	190	190	192	192	192	191	0.57
EXHST TEMP (C):	445.6	446	446.3	446.6	446.9	446	0.11
HC (ppm) :	10	10	10	10	10	10.0	0.00
CO (%) :	0.02	0.02	0.02	0.02	0.02	0.020	0.00
CO2 (%) :	7.44	7.40	7.40	7.40	7.42	7.41	0.24
O2 (%) :	9.65	9.66	9.63	9.60	9.60	9.63	0.29

CARB FLOW(g/s): 10.541 10.481 10.535 10.533 10.559 10.530 0.27

REYNOLDS NR. : 4.54E+04

TREATED TEST DATE : 25.10.92

ENG. HOURS : 1326 ENG. RPM:
 AMB. TEMP (C) : 44.4 STACK(mm): 200
 BAROMETRIC(mb): 958 LOAD: 580 KW

	TEST 1	TEST 2	TEST 3	TEST 4	TEST 5	AVERAGE	% ST.DEV
PRES DIFF (Pa):	170	171	168	169	168	169	0.77
EXHST TEMP (C):	468.5	468.5	468.5	468.5	468.5	469	0.00
HC (ppm) :	0	0	0	0	0	0.0	#DIV/0!
CO (%) :	0.04	0.04	0.04	0.04	0.04	0.040	0.00
CO2 (%) :	7.68	7.69	7.68	7.69	7.69	7.69	0.07
O2 (%) :	9.72	9.72	9.72	9.72	9.72	9.72	0.00

CARB FLOW(g/s): 10.111 10.153 10.051 10.094 10.064 10.094 0.40

REYNOLDS NR. : 4.19E+04 TOTAL HOURS ON TREATED FUEL : 504

PERCENTAGE CHANGE IN FUEL CONSUMPTION ((TREATED-BASE)/BASE*100) : -4.1 %

REMARKS:

FUEL TECHNOLOGY PTY LTD

CARBON BALANCE RESULTS

COMPANY : BELLEVUE GOLD MINE LOCATION : LEINSTER
 EQUIPMENT : GENSET UNIT NR. : 3 L/Bank
 ENG. TYPE : CUMMINS MODEL : KTA50
 RATING : FUEL : ADO

BASELINE DATE : 4.10.92

 ENG. HOURS : 822 ENG. RPM:
 AMB. TEMP (C) : 27.2 STACK(mm): 200
 BAROMETRIC(mb): 965 LOAD: 590-600 KW

	TEST 1	TEST 2	TEST 3	TEST 4	TEST 5	AVERAGE	% ST.DEV	
PRES DIFF (Pa):	198	197	198	196	198	197	0.45	
EXHST TEMP (C):	465.1	465.6	465.8	466	466.3	466	0.10	
HC (ppm) :	10	10	10	10	10	10.0	0.00	
CO (%) :	0.03	0.03	0.03	0.03	0.03	0.030	0.00	
CO2 (%) :	7.88	7.87	7.89	7.90	7.88	7.88	0.14	
O2 (%) :	9.07	9.09	9.07	9.07	9.07	9.07	0.10	
CARB FLOW(g/s):	11.258	11.212	11.267	11.222	11.249	11.242	0.21	
REYNOLDS NR. :	4.55E+04							

TREATED TEST DATE : 25.10.92

 ENG. HOURS : 1326 ENG. RPM:
 AMB. TEMP (C) : 44.3 STACK(mm): 200
 BAROMETRIC(mb): 958 LOAD: 580 KW

	TEST 1	TEST 2	TEST 3	TEST 4	TEST 5	AVERAGE	% ST.DEV	
PRES DIFF (Pa):	163	163	164	163	163	163	0.27	
EXHST TEMP (C):	471.9	472.1	472.3	472.3	472.3	472	0.04	
HC (ppm) :	0	0	0	0	0	0.0	#DIV/0!	
CO (%) :	0.04	0.04	0.04	0.04	0.04	0.040	0.00	
CO2 (%) :	7.77	7.77	7.78	7.78	7.78	7.78	0.07	
O2 (%) :	9.89	9.89	9.89	9.89	9.89	9.89	0.00	
CARB FLOW(g/s):	9.991	9.990	10.032	10.001	10.001	10.003	0.17	
REYNOLDS NR. :	4.10E+04	TOTAL HOURS ON TREATED FUEL :				504		

PERCENTAGE CHANGE IN FUEL CONSUMPTION ((TREATED-BASE)/BASE*100) : -11.0 %

REMARKS:

COMPANY : BELLEVUE GOLD MINE

LOCATION : LEINSTER

EQUIPMENT : GENSET

UNIT NR. : 5 R/Bank

ENG. TYPE : CUMMINS

MODEL : KTA50

RATING :

FUEL : ADO

BASELINE

DATE : 4.10.92

ENG. HOURS : 34746.5

ENG. RPM:

AMB. TEMP (C) : 27.2

STACK(mm): 200

BAROMETRIC(mb): 966

LOAD: 560-600 KW

	TEST 1	TEST 2	TEST 3	TEST 4	TEST 5	AVERAGE	% ST.DEV
PRES DIFF (Pa):	199	197	200	199	197	198	0.68
EXHST TEMP (C):	416.4	416.5	416.5	416.6	416.7	417	0.03
HC (ppm) :	10	10	10	10	10	10.0	0.00
CO (%) :	0.02	0.02	0.02	0.02	0.02	0.020	0.00
CO2 (%) :	7.44	7.40	7.40	7.40	7.40	7.41	0.24
O2 (%) :	9.63	9.63	9.61	9.61	9.60	9.62	0.14

CARB FLOW(g/s): 11.019 10.905 10.987 10.959 10.903 10.955 0.47

REYNOLDS NR. : 4.72E+04

TREATED TEST

DATE : 25.10.92

ENG. HOURS : 35215

ENG. RPM:

AMB. TEMP (C) : 38.6

STACK(mm): 200

BAROMETRIC(mb): 957

LOAD: 560-580 KW

	TEST 1	TEST 2	TEST 3	TEST 4	TEST 5	AVERAGE	% ST.DEV
PRES DIFF (Pa):	181	183	180	180	181	181	0.68
EXHST TEMP (C):	418.9	419.4	420	420	420.1	420	0.12
HC (ppm) :	20	20	20	20	20	20.0	0.00
CO (%) :	0.03	0.03	0.03	0.03	0.03	0.030	0.00
CO2 (%) :	7.19	7.15	7.15	7.15	7.15	7.16	0.25
O2 (%) :	10.45	10.45	10.45	10.45	10.45	10.45	0.00

CARB FLOW(g/s): 10.110 10.106 10.019 10.019 10.046 10.060 0.45

REYNOLDS NR. : 4.48E+04

TOTAL HOURS ON TREATED FUEL : 468.5

PERCENTAGE CHANGE IN FUEL CONSUMPTION ((TREATED-BASE)/BASE*100) : -8.2 %

REMARKS:

FUEL TECHNOLOGY PTY LTD

CARBON BALANCE RESULTS

COMPANY : BELLEVUE GOLD MINE LOCATION : LEINSTER

EQUIPMENT : GENSET UNIT NR. : 5 L/Bank
 ENG. TYPE : CUMMINS MODEL : KTA50
 RATING : FUEL : ADO

BASELINE DATE : 4.10.92

ENG. HOURS : 34746.5 ENG. RPM:
 AMB. TEMP (C) : 27.2 STACK(mm): 200
 BAROMETRIC(mb): 966 LOAD: 570-590 KW

	TEST 1	TEST 2	TEST 3	TEST 4	TEST 5	AVERAGE	% ST.DEV
PRES DIFF (Pa):	191	192	190	191	190	191	0.44
EXHST TEMP (C):	421.3	421.5	421.7	421.8	421.8	422	0.05
HC (ppm) :	10	10	10	10	10	10.0	0.00
CO (%) :	0.02	0.02	0.02	0.02	0.02	0.020	0.00
CO2 (%) :	7.38	7.37	7.37	7.38	7.38	7.38	0.07
O2 (%) :	9.00	8.99	8.98	8.97	8.96	8.98	0.18
CARB FLOW(g/s):	10.676	10.688	10.631	10.672	10.645	10.662	0.22
REYNOLDS NR. :	4.61E+04						

TREATED TEST DATE : 25.10.92

ENG. HOURS : 35215 ENG. RPM:
 AMB. TEMP (C) : 38.6 STACK(mm): 200
 BAROMETRIC(mb): 957 LOAD: 580 KW

	TEST 1	TEST 2	TEST 3	TEST 4	TEST 5	AVERAGE	% ST.DEV
PRES DIFF (Pa):	179	180	179	178	179	179	0.40
EXHST TEMP (C):	423.1	423.2	423.2	423.4	423.5	423	0.04
HC (ppm) :	10	10	10	10	10	10.0	0.00
CO (%) :	0.04	0.04	0.04	0.04	0.04	0.040	0.00
CO2 (%) :	7.02	7.02	7.05	7.04	7.06	7.04	0.25
O2 (%) :	10.34	10.34	10.34	10.34	10.34	10.34	0.00
CARB FLOW(g/s):	9.796	9.823	9.837	9.794	9.848	9.819	0.25
REYNOLDS NR. :	4.44E+04	TOTAL HOURS ON TREATED FUEL :		468.5			

PERCENTAGE CHANGE IN FUEL CONSUMPTION ((TREATED-BASE)/BASE*100) : -7.9 %

REMARKS:

SPECIFIC FUEL CONSUMPTION
DATA SHEETS

FUEL TECHNOLOGY PTY. LTD.

FOR: BELLEVIEW GOLD MINE

ENGINE NO. 2

Date: Base 4-10-92

DIESEL GENERATING UNIT DATA TEST SHEET

Location _____

Treated _____

ENGINE:

Make Cummins

ALTERNATOR:

Make _____

0.826/32.8

Density @ 15°: Base _____

Model KTA 50

Model _____

Treated _____

Serial No _____

Serial No _____

Flash Point PM

Closed Cup _____

Eng Hrs Start 778 Finish _____

Rating _____

TIME P.M. Start Finish	Δ T	Nom. Load Kw	KWh Start Finish x10	Δ KWh	Kw. Av.	Kv Volts	Amps	FUEL Start Finish	Fuel ltrs.	Kwhr/kg L/kwh	TEMPERATURES °C				
											E.Gas	Air In Dry Wet	J.W. Out In	LO	
8.21		516	3544.539			437	706	1197890.0				18/13			
8.36	15	517	3672.714	128.175	512.7	437	711	11979266	36.6	0.2855		18/13			
8.51	15	510	3800.599	127.885	511.4	437	704	1197963.1	36.5	0.2854		18/13			
9.06	15	505	3927.219	126.62	506.5	437	696	1197999.3	36.2	0.2858		18/13			
9.21	15	497	4053.307	126.088	504.4	437	689	1198035.5	36.2	0.2871		18/13			
				508.768					145.5	0.2859					
SUGGEST RUN TREATED TRIALS ON NEW ENGINES AT SAME TIME															
LOAD VERY STEADY.															

